

(43)

Government of Andhra Pradesh
A.P. State Disaster Response and Fire Services Department

Periodical Renewal Fire Certificate

From:
District Disaster Response & Fire
Officer
Andhra Pradesh, West Godavari

To:
DISTRICT EDUCATIONAL
OFFICER, REGISTER, ADIKAVI
NANNAYYA
UNIVERSITY, BOARD OF
INTERMEDIATE EDUCATION..

File No: 32940/WGV/DFO/2026, Date:02/07/2026

Occupancy NOC RC Number: R.C NO:1741/A1/2017, DATE:04/11/2017


Sir,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Periodical Fire Certificate to the existing Non Multi Storeyed Building of **VIVEKANANDA EM HIGH SCHOOL, S.D COLLEGE OF I.T.S.K.S.D MAHILA KALASALA (JUNIOR)**, represented by **SRI VENKATA KRISHNA EDUCATIONAL SOCIETY, D.NO:10-1-16,39, R.S NO:372/ 2, OLD TOWN, TANUKU, WEST GODAVARI DISTRICT, AP.** - Regarding.


- Ref:
1. G.O.Ms.NO.218 Home (Prisons & Fire) Department, Dated.22-12-2023
 2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.02-05-2023.
 3. This Office NOC for Occupancy Rc No. R.C NO:1741/A1/2017, DATE:04/11/2017, Dt.04/11/2017
 4. Renewal NOC For Occupancy R.C NO:1741/A1/2017, DATE:04/11/2017, Dt.05/01/2021
 5. Online Application for Renewal NOC of SRI VENKATA KRISHNA EDUCATIONAL SOCIETY, D.NO:10-1-16,39, R.S NO:372/ 2, OLD TOWN, TANUKU, WEST GODAVARI DISTRICT, AP. - Inspection report called for Regarding.
 6. Online Inspection Report submitted by Officers of this Department on 01-07-2026.

-- X --

The Management of **VIVEKANANDA EM HIGH SCHOOL, S.D COLLEGE OF I.T.S.K.S.D MAHILA KALASALA (JUNIOR)**, represented by **SRI VENKATA KRISHNA EDUCATIONAL SOCIETY, D.NO:10-1-16,39, R.S NO:372/ 2, OLD TOWN, TANUKU, WEST GODAVARI DISTRICT, AP.** has requested to issue Periodical Fire Certificate duly remitting the Fire Precautionary fee for Rs.146270/- vide challan No. 11103556262026, Dated 25/06/2026 at ONLINE PAYMENT.


Principal
Vivekananda E.M. High School
10-16-39, Old Town, Peravali Road,
TANUKU, W.G.District, A.P-534 211

Smt. Akkayamma Educational and
Charitable Society


President/Correspondent

VIVEKANANDA EM HIGH SCHOOL, S.D COLLEGE OF I.T,S.K.S.D MAHILA KALASALA (JUNIOR)

1. This certificate is being issued as per G.O.Ms.No:218,Home(Prisons & Fire),Dt:22-12-2023
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Periodical Renewal Fire Certificate for vide reference 4th cited to the existing Non Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Periodical Renewal Fire Certificate **SRI VENKATA KRISHNA EDUCATIONAL SOCIETY**
D.NO:10-1-16,39,R.S NO:372/ 2,OLD TOWN,TANUKU,WEST GODAVARI
DISTRICT,AP., subject to the following conditions.

Sl	As Builder	As Occupant	As Security Personnel
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/ blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.


The applicant/management must train 40% of their total work force on 3 days Basic Firefighting Course under AP Fire Services and Civil Defence Training Institute, Sattenapalli or Regional Training Centres of the Department.

4. This Periodical Renewal Fire Certificate is valid from 02/07/2026 to 01/07/2031.

5. The Responsibility/liability of the owner/occupant to maintain Fire safety in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.


Principal

Vivekananda E.M. High School
10-16-39, Old Town, Peravali Road,
TANUKU, W.G. District, A.P-534 211

Smt. Akkayamma Educational and Charitable Society

President/Correspondent

6. Challan Info:

Challan Number	Challan Date	Challan Amount
11103556262026	2026-06-25	146270

The following deficiencies/suggestions are identified by the officers of the department and needs to be attended to by the management.

The Inspection Committee consisting of FSIO Tanuku Fire Station Stated in his Report: It is respectfully submitted that the management has provided sufficient open spaces on the northern and eastern sides of the building, whereas the required open spaces have not been provided on the southern and western sides. The management has provided sufficient means of escape. The firefighting equipment has been provided in accordance with Occupancy NOC Rc. No. 1741/A1/2017, dated 04.11.2017, and the same was found to be in good working condition during the time of inspection.

The Management is requested that, The Provided Fire Fighting equipment should be maintained always in good working Condition.

"Safe School, Safe Hospital & Fire Safety Society-Together for Fire Prevention"

"सुरक्षित विद्यालय, सुरक्षित अस्पताल एवं अग्नि सुरक्षा के प्रति जागरूक समाज आग की रोकथाम के लिए एक साथ"

"సురక్షిత పాఠశాలలు, సురక్షితమైన ఆసుపత్రులు మరియు అగ్నిమాపక భద్రతపై స్పృహ ఉన్న సమాజం మంటలను నివారించడానికి కలిసి పనిచేస్తాయి."



Your Sincerely,

[Signature]
02/07/2026

District Disaster Response & Fire Officer,
West Godavari District

In case of emergency, please call 101 or 08819-222101 or 9963725758

Copy to Management SRI VENKATA KRISHNA EDUCATIONAL SOCIETY,
D.NO:10-16-39,R.S NO:372/ 2,OLD TOWN,TANUKU,WEST GODAVARI
DISTRICT,AP.

Copy to Assistant District Fire Officer Concerned
Copy to Station Fire Officer Concerned

For Smt. Akkayamma Educational and
Charitable Society

ch.S. v R

President/Correspondent

[Signature]

Principal

Vivekananda E.M. High School
10-16-39, Old Town, Peravali Road,
TANUKU, W.G.District, A.P-534 211.